



Certificate number: 2304712 (1)

Issued 23/03/2023

Expires 23/03/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

BSS Industrial.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
BSS Industrial
Cross Point Business Park
Ashcroft Way
Coventry
CV2 2TU
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2304712

The following products belong to this certificate

PRODUCT DESCRIPTION Range of BA type verifiable reduced pressure zone valves with bronze bodies. The valves incorporate two spring loaded check valve cartridges & the zone between the two valves incorporates a stainless-steel spring and NBR seal. A quarter turn spherical valve is located in each zone to act as a test port. The discharge port is fitted with a tundish. ATS3 – Without Production Surveillance.
MODEL(S) 36700376; 36700387; 36700398; 36700406.
SIZE: 50mm, 65mm, 80mm & 100mm flanged connection.
SCOPE: Manufacturer recommended maximum working pressure 16 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C. Above ground use only.
MARKING BOSS on ID Tag.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. The fitting is to be so installed as to be readily accessible for examination, test, maintenance, replacement or operation. Notification should be given in writing of the proposed installation of this fitting to the local Water Supplier prior to its installation. The fitting shall not be installed until consent is given by the Water Supplier in line with Regulation 5 of the Water Supply (Water Fittings) Regulations 1999 or the Water Supply (Water Fittings) Regulations (Northern Ireland) 2009, or Byelaw 5 of the Water Supply (Water Fittings) (Scotland) Byelaws 2014. Extra Notes: Having obtained consent from the water supplier for the installation of a BA device (RPZ valve) as required by Regulation 5 of the Water Supply (Water Fittings) Regulations 1999; the installation of the BA device (RPZ valve) and any associated fittings must be installed in accordance with the water suppliers "Approved Installation Method" AIM-08-01.

Extra Notes