



Certificate number: 2201721 (1)

Issued 11/01/2022

Expires 30/11/2026

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

BSS Industrial.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

BSS Industrial
BOSS Court
7 Barton Close
Grove Park
Leicester
LE19 1SJ



Product Certificate

Appendix to Certificate number: 2201721

The following products belong to this certificate

| |
|---|
| PRODUCT DESCRIPTION Range of bronze bodied pre-set pressure relief valves (available between 0.2-16 bar on each model) incorporate a manually operated easing gear with brass seat and PTFE or EPDM washers. ATS3 – Without Production Surveillance. |
| MODEL(S) BOSS 957 15mm x 15mm BOSS 959 15mm x 20mm BOSS 957 20mm x 20mm BOSS 959 20mm x 25mm BOSS 957 25mm x 25mm BOSS 959 25mm x 32mm BOSS 957 32mm x 32mm BOSS 959 32mm x 40mm BOSS 957 40mm x 40mm BOSS 959 40mm x 50mm BOSS 957 50mm x 50mm |
| SIZE: See model. |
| SCOPE: Manufacturer recommended maximum working pressure 16 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C. Above ground use only. |
| MARKING Boss & Fig No, date of manufacture (MM/YY) size, model, set pressure on date label. Flow arrow, DN moulded on body. |
| MATERIALS Non-metallic materials assessed (BS6920) to point of discharge. |
| BACKFLOW PROTECTION NOTES N/A. |
| ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements. |

Extra Notes



Pipeline & Heating Solutions

BOSS Court
7 Barton Close
Leicester
LE19 1SJ
T: 0116 245 5500
F: 0116 253 1343
E: reception@bssgroup.com
W: www.bssindustrial.co.uk

December 2021

WRAS and REG4 Information Letter

The purpose of this letter is to clarify the status of WRAS and REG4 Certification.

Background

All manufacturers selling water supply products into the UK must meet Regulation 4, a section in these regulations:

- Water Supply (Water Fittings) Regulations 1999
- The Water Supply (Water Fittings) (Scotland) Byelaws 2014
- The Water Supply (Water Fittings) Regulations (Northern Ireland) 2009

Historically, the only (widely accepted) way to demonstrate this compliance has been via the Water Regulations Approval Scheme (WRAS).

Recent Developments

Over the last 12 months, a new pathway has been created for manufacturers to obtain independent verification of compliance with the legislation. That new pathway being direct certification by the testing bodies; NSF and KIWA UK.

Comparison

All three schemes independently verify that fittings comply with the required legislation and have equal standing in this regard.



Best Regards.

Benjamin Cockerill

Ben Cockerill PCQI - Quality Manager - 07392 109053 -
benjamin.cockerill@travisperkins.co.uk