



Flamco

Your Reliable Partner

- Unvented Systems
- Pressurisation Units
- Expansion Systems
- Air & Dirt Removal
- Renewable Energy Solutions
- Pipe Support Systems
- Valves Fittings & Controls
- Training and Development

EC Declaration of Conformity according to the Pressure Equipment Directive 97/23/EC of the European Parliament and the Council of 29 May 1997

Manufacturer	CIMM spa Via Caprera 13 31030 Castello di Godego Italy	Factor	Flamco Limited Washway Lane St Helens Merseyside WA10 6PB
---------------------	--	---------------	---

Notified Body	BUREAU VERITAS ITALIA S.P.A. Via Miramare, 15 20126 - MILANO Country : Italy
----------------------	---

Range Name	BOSS Potable (Potable Expansion Vessels)
-------------------	--

Range & Rating	2 litre 10 bar, 100 °C	3 litre 10 bar, 100 °C
	5 litre 10 bar, 100 °C	8 litre 10 bar, 100 °C
	12 litre 10 bar, 100 °C	16 litre 10 bar, 100 °C
	18 litre 10 bar, 100 °C	24 litre 10 bar, 100 °C
	35 litre 10 bar, 100 °C	50 litre 10 bar, 100 °C
	60 litre 10 bar, 100 °C	80 litre 10 bar, 100 °C
	100 litre 10 bar, 100 °C	150 litre 10 bar, 100 °C
	200 litre 10 bar, 100 °C	300 litre 10 bar, 100 °C
	500 litre 10 bar, 100 °C	750 litre 8 bar, 100 °C
	1000 litre 8 bar, 100 °C	
	750 litre 10 bar, 50 °C	1000 litre 10 bar, 50 °C

The following Conformity Assessment Modules are used for the below mentioned expansion vessels

Conformity Assessment Modules followed for Category I, II, III, IV	B and D
Marking Identification number on label	CE 1370
Maximum allowable working condition	see attached label
Medium	water/ gas
Fluid classification (Group) according to article 9	2
Applicable table PED appendix II	2
Harmonized standard applied	EN 13831

Rob Clemson Beng Hons MIEE Chartered Engineer
Technical Manager Flamco UK Limited