



*Certificate number: 2304713 (2)*

Issued 13/06/2023

Expires 20/02/2028

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### BSS Industrial.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to:**  
BSS Industrial  
Cross Point Business Park  
Ashcroft Way  
Coventry  
CV2 2TU  
United Kingdom



**KUKreg4**

# Product Certificate

Appendix to Certificate number: 2304713

The following products belong to this certificate

<p><b>PRODUCT DESCRIPTION</b></p> <p>Range of BA type verifiable reduced pressure zone valves with bronze or DZR brass bodies. The valves incorporate two spring loaded check valve cartridges &amp; the zone between the two valves incorporates a spring-loaded relief valve. A quarter turn spherical valve is located in each zone to function as a test port.</p> <p>Model: ATS3 – Without Production Surveillance.</p>
<p><b>MODEL(S)</b></p> <p>BOSS 574 RPZ Valve 36700310; 36700321; 36700332; 36700343; 36700354; 36700365.</p>
<p><b>SIZE:</b></p> <p>½" to 2" BSP (M).</p>
<p><b>SCOPE:</b></p> <p>Manufacturer recommended maximum working pressure 10 Bar &amp; maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C. Above ground use only.</p>
<p><b>MARKING</b></p> <p>Boss on ID Tag.</p>
<p><b>MATERIALS</b></p> <p>Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p><b>BACKFLOW PROTECTION NOTES</b></p> <p>N/A.</p>
<p><b>ADDITIONAL NOTES</b></p> <p>All water contact &amp; exposed components satisfy opacity requirements.</p> <p>The fitting is to be so installed as to be readily accessible for examination, test, maintenance, replacement, or operation.</p> <p>Notification should be given in writing of the proposed installation of this fitting to the local Water Supplier prior to its installation. The fitting shall not be installed until consent is given by the Water Supplier in line with Regulation 5 of the Water Supply (Water Fittings) Regulations 1999 or the Water Supply (Water Fittings) Regulations (Northern Ireland) 2009, or Byelaw 5 of the Water Supply (Water Fittings) (Scotland) Byelaws 2014.</p> <p>Having obtained consent from the water supplier for the installation of a BA device (RPZ valve) as required by Regulation 5 of the Water Supply (Water Fittings) Regulations 1999; the installation of the BA device (RPZ valve) and any associated fittings must be installed in accordance with the water suppliers "Approved Installation Method" AIM-08-01.</p>

## Extra Notes